

--	--

Applicant Name:	
Applicant Phone & email:	
Contractor Name:	License Number & Type:
Contractor Phone & email:	
Owner Name:	
Owner Phone & email:	

EVSE Charging Level: <input type="checkbox"/> Level 1 (120V) <input type="checkbox"/> Level 2 (240V) <input type="checkbox"/> Level 3 (480V)	
Maximum Rating (Nameplate) of EV Service Equipment = _____ kW	
Voltage EVSE = _____ V	Manufacturer of EVSE: _____
Mounting of EVSE: <input type="checkbox"/> Wall Mount <input type="checkbox"/> Pole Pedestal Mount <input type="checkbox"/> Other _____	

System Voltage: <input type="checkbox"/> 120/240V, 1 ϕ , 3W <input type="checkbox"/> 120/208V, 3 ϕ , 4W <input type="checkbox"/> 120/240V, 3 ϕ , 4W <input type="checkbox"/> 277/480V, 3 ϕ , 4W <input type="checkbox"/> Other _____	
Rating of Existing Main Electrical Service Equipment = _____ Amperes	
Rating of Panel Supplying EVSE (if not directly from Main Service) = _____ Amps	
Rating of Circuit for EVSE: _____ Amps / _____ Poles	

AIC Rating of EVSE Circuit Breaker (if not Single Family, 400A) = _____
A.I.C.
(or verify with Inspector in field)

Specify Either Connected, Calculated or Documented Demand Load of Existing Panel:

• Connected Load of Existing Panel Supplying EVSE = _____ Amps

• Calculated Load of Existing Panel Supplying EVSE = _____ Amps

• Demand Load of Existing Panel or Service Supplying EVSE = _____ Amps
(Provide Demand Load Reading from Electric Utility)

Total Load (Existing plus EVSE Load) = _____ Amps

For Single Family Dwellings, if Existing Load is not known by any of the above methods, then the Calculated Load may be estimated using the "Single-Family Residential Permitting Application Example" in the Governor's Office of Planning and Research "Zero Emission Vehicles in California: Community Readiness Guidebook" <https://www.opr.ca.gov>

EVSE Rating _____ Amps x 1.25 = _____ Amps = Minimum
Ampacity of EVSE Conductor = # _____ AWG

For Single-Family: Size of Existing Service Conductors = # _____ AWG or
kcmil

- or - : Size of Existing Feeder Conductor
Supplying EVSE Panel = # _____ AWG or
kcmil

(or Verify with Inspector in field)

I hereby acknowledge that the information presented is a true and correct representation of existing conditions at the job site and that any causes for concern as to life-safety verifications may require further substantiation of information.

Signature of Permit Applicant: _____ Date: _____

09-30-2016

Level 2 Electric Vehicle Charger Service Load Calculator

INSTRUCTIONS: Review the list of electrical loads in the table below and check all that exist in your home (don't forget to include the proposed Level 2 charger). For each item checked, fill in the corresponding "Watts Used" (refer to the "Typical Usage" column for wattage information). Add up all of the numbers that are written in the "Watts Used" column and write that number in the "TOTAL WATTS USED" box at the bottom of the table. Then go to the next page to determine if your existing electric service will accommodate the new loads.

(Loads shown are rough estimates; actual loads may vary. For a more precise analysis, use the nameplate ratings for appliances and other loads and consult with a trained electrical professional.)

Check all Applicable Loads (✓)	Description of Load	Typical Usage	Watts Used
GENERAL LIGHTING AND RECEPTACLE OUTLET CIRCUITS			
	Multiply the square footage of house x 3	3 watts/sq. ft.	
KITCHEN CIRCUITS			
	Kitchen circuits	3,000 watts	
	Electric oven	2,000 watts	
	Electric stove top	5,000 watts	
	Microwave	1,500 watts	
	Garbage disposal under kitchen sink	1,000 watts	
	Automatic dish washer	3,500 watts	
	Garbage compactor	1,000 watts	
	Instantaneous hot water at sink	1,500 watts	
LAUNDRY CIRCUITS			
	Laundry circuit	1,500 watts	
	Electric clothes dryer	4,500 watts	
HEATING AND AIR CONDITIONING CIRCUITS			
	Central heating and air conditioning	6,000 watts	
	Window mounted air conditioning	1,000 watts	
	Whole-house or attic fan	500 watts	
	Central electric furnace	8,000 watts	
	Evaporative cooler	500 watts	
OTHER ELECTRICAL LOADS			
	Electric water heater (storage type)	4,000 watts	
	Electric tankless water heater	15,000 watts	
	Swimming pool or spa	3,500 watts	
	Other (describe)		
	Other (describe)		
	Other (describe)		
ELECTRIC VEHICLE CHARGER CIRCUIT			
	Level 2 electric vehicle charger wattage rating		
			TOTAL WATTS USED

INSTRUCTIONS: Using the "TOTAL WATTS USED" number from the previous page, check the appropriate line in column 1 and follow that line across to determine the minimum required size of the electrical service panel shown in column 3. In column 4, write in the size of your existing service panel (main breaker size). If your existing service panel (column 4) is smaller than the minimum required size of the existing service (column 3), then you will need to install a new upgraded electrical service panel to handle the added electrical load from the proposed Level 2 charger.

The table below is based on CEC 220.83(A), 230.42 and Annex D.

1	2	3	4
Check the appropriate line (✓)	Total Watts Used (from previous page)	Minimum Required Size of Existing 240-Volt Electrical Service Panel (Main Service Breaker Size)	Identify the Size of Your Existing Main Service Breaker (Amps)*
	up to 48,000	100 amps	
	48,001 to 63,000	125 amps	
	63,001 to 78,000	150 amps	
	78,001 to 108,000	200 amps	
	108,001 to 123,000	225 amps	

*Note that the size of your existing service (column 4) MUST be equal to or larger than the Minimum Required Size (column 3) or a new larger electrical service panel will need to be installed in order to satisfy the electrical load demand of the EV charger.

STATEMENT OF COMPLIANCE

By my signature, I attest that the information provided is true and accurate.

Job Address: _____
(Print job address)

Signature: _____
(Signature of applicant) (Date)

In addition to this document, you will also need to provide a copy of the manufacturer's installation literature and specifications for the Level 2 charger you are installing.

Note: This is a voluntary compliance alternative and you may wish to hire a qualified individual or company to perform a thorough evaluation of your electrical service capacity in lieu of this alternative methodology. Use of this electrical load calculation estimate methodology is at the user's risk and carries no implied guarantee of accuracy. Users of this methodology and these forms are advised to seek professional assistance in determining the electrical capacity of a service panel.